



Heating & Cooling, Inc.

Furnace Clean & Check

Name	Email
Street	Make
City/State/Zip	Model
Phone	Serial Number

- | | |
|---|---|
| <ul style="list-style-type: none"> Test and adjust gas pressure if needed Clean and inspect condensate trap Perform an in-home carbon monoxide check All gas test port plugs and caps reinstalled and sealed Combustion exhaust vent pipes reinstalled and secured properly Condensate put back together properly Condensate hoses reattached, secured, and draining to proper location Unit starts by itself with the thermostat after the C & C without any jumper wires Power tuned back on to unit before leaving Thermostat set back to where homeowner had originally Inspect and tighten all electrical connections and terminals Insure correct supply voltage at rest, start, and run Inspect Air Filter Suggest Battery replacement for Thermostat Inspect, clean, and adjust ignition/pilot system Inspect heat-exchanger(s) & combustion chamber for cracks, rusting, or problems Clean blower compartment, return box, and surrounding area Inspect main blower and blower wheel Lubricate motor and fan bearings as well as other moving parts as necessary Measure and record electrical voltage, amperage, and component resistance Inspect and test all system transformers, relays, switches, and safety controls Inspect the flue assembly and vent piping and flue drafting | <ul style="list-style-type: none"> Test exhaust for proper combustion readings Clean and inspect condensate drain lines Inspect Humidifier Check Thermostat for proper operation Clean and adjust main gas burners Clean combustion chamber |
|---|---|

Technician Comments

Technician Signature

Customer Signature

Signature Date



87 West Beltline Highway
Madison, WI 53713
HarkerHeating.com



e. info@HarkerHeating.com
t. 608.255.6902
f. 608.255.2001

Commercial Residential Service Sales